


Rotary Gas Meters RM40 - Soft Metric







Note: AMI/AMR adaptors available upon request.

| METER SIZE | А | В | С | D1 | D1 (no Mag. Hsg) | D2 | D3 | D4 | E1 | WEIGHT (lbs) |
|---------------|--------|----------|-------|--------|---------------------|--------|--------|--------|-------|--------------|
| RM40 | 10.50" | 1.5" NPT | 3.44" | 11.29" | 8.83" | 12.77" | 13.60" | 14.49" | 4.00" | 13-16 |

SOFT METRIC RM40 1.5" NPT CONNECTION TECHNICAL SPECIFICATION


| Connection (Threaded) | NPT | 1.5" |
|---|------------|-----------|
| MAOP | (kPa) | 1206/1400 |
| Flow Capacity | (m³/h) | 40 |
| Rangeability* (up to 1:160 @ atmospheric condition) | | 1:160 |
| Start Rate | (m³/h) | .056 |
| Stop Rate | (m³/h) | .042 |
| Differential @ 100 % Flow [AIR/N.G.] | (Pa) | 169 |
| Instrument Drive Rate | (m³/rev) | .1 |
| LF Pulser (Optional) | (m³/pulse) | .1 |

^{*}Note: It should be noted, that moving parts in the meters with a greater rangeability ratio are made to high class accuracy and tight tolerances.

Improper installation, stresses on piping system due to temperature changes, settling and gas conditions can create a risk of meter rejection.

CORRECTED FLOW CAPACITY AND TYPICAL ACCURACY GUIDE

| RM40 METER (SM³/H) | | | | |
|----------------------------------|---------------------------|--|--|--|
| Gauge Pressure kPa 1.72 | RM40 Qmax = 40m³/hr | | | |
| 5 | 41.8 | | | |
| 10 | 43.8 | | | |
| 50 | 59.6 | | | |
| 100 | 79.3 | | | |
| 150 | 99.1 | | | |
| 200 | 118.8 | | | |
| 250 | 138.6 | | | |
| 300 | 158.3 | | | |
| 500 | 237.2 | | | |
| 750 | 335.9 | | | |
| 1000 | 434.6 | | | |
| 1100 | 474.1 | | | |
| 1200 | 513.6 | | | |





The values quoted are typical of normal production. They do not constitute a specification. Romet Limited reserves the right to change any information in this literature without notice. All of the information and data in this literature has been carefully compiled and thoroughly checked. However, Romet Limited will not assume responsibility for any possible omissions or errors.